


## U6585-X-2/200-K3L



| Catalog Number                | U6585-X-2/200-K3L  |
|-------------------------------|--|
| Marketing Product Description | 4 Terminal Ringless Large<br>Closing Plate 2-200 Ampere<br>Main Breaker Single<br>Connector Locking 4-600kcmil |
| UPC                           | 78457298226  |
| Length (IN)                   | 4.844  |
| Width (IN)                    | 20.25  |
| Height (IN)                   | 45.00  |
| Brand Name                    | Milbank  |
| Туре                          | Ringless Meter Socket  |
| Application                   | Meter Socket With Main   |
| Standard                      | UL Listed;Type 3R  |
| Voltage Rating                | Up to 240 Volts Alternating<br>Current   |
| Amperage Rating               | 320 Continuous Ampere  |
| Phase                         | 1 Phase  |
| Frequency Rating              | 60 Hertz   |
| Size                          | 4.844L x 20.25W x 45H  |
| Number Of Cutouts             | 2  |
| Cutout Size                   | Two 200 Ampere Main<br>Breakers  |
| Cable Entry                   | Overhead or Underground  |
| Terminal                      | Single Mechanical  |
| Insulation                    | Glass Polyester  |

| Mounting                  | Surface Mount                                   |
|---------------------------|---|
| Enclosure                 | G90 Galvanized Steel with<br>Powder Coat Finish |
| Jaw Quantity              | 4 Terminal                                      |
| Bypass Type               | Lever Bypass                                    |
| Number of Meter Positions | 1 Position                                      |
| Equipment Ground          | Ground Bar                                      |
| Hub Opening               | Large Closing Plate                             |
| Line Side Wire Range      | 4 AWG - 600 kcmil or Two 1/0<br>AWG - 250 kcmil |
| Load Side Wire Range      | 1 AWG - 300 kcmil                               |
| Number Of Receptacles     | 0   |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.