



# NEW: Meter Disconnect Combo

UL Listed | 60 Amps



*Looks better, installs faster...  
a meter socket and a  
disconnect in one box!*

## Features

- Easy installation
  - All-in-one saves time
- Durable enclosure
  - NEMA 3R rated
  - Powder-coated galvanized steel, aluminum, or stainless steel
- Available in a range of styles (stainless steel hasp, isolated neutral, barrel lock, etc)
- SCCR Rating of 10K
- UL listed
- Manufactured in the USA

*Replace  
cumbersome  
installations!*



| Catalog Number | Amps | Meter Type | Lever Bypass | Dimensions |    |        |
|----------------|------|------------|--------------|------------|----|--------|
|                |      |            |              | D"         | W" | H"     |
| U6419*         | 60   | Ringless   | No           | 4 19/32    | 8  | 16     |
| U6420*         | 60   | Ring-type  | No           | 4 19/32    | 8  | 16     |
| U6421*         | 60   | Ringless   | Yes          | 4 19/32    | 10 | 19 3/8 |

Add prefix for below options:  
**USS-** stainless steel (No KOs or hub openings are included in the enclosure from the factory when ordered as stainless steel)  
**UAP-** aluminum painted

\*Add suffix for below options:  
**-HSP** stainless steel hasp  
**-INS** isolated neutral  
**-BL** barrel lock  
**-IL** barrel lock  
**-BLG** barrel lock/guard provisions  
**-KK** horn bypass

## Common Applications



Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.






MILBANK  
ENERGY AT WORK


# NEW: Meter Disconnect Combo

UL Listed | 60 Amps



6419



6421



6420



Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.

