

U1253-X-K3



| U1253-X-K3 |
|---|
| 4 Terminal Ringless Large Closing Plate 3 Position Single Connector 4-600kcmil |
| 784572133495 |
| 5.125 |
| 34.5 |
| 14 |
| Milbank |
| Ringless Meter Socket |
| Meter Socket |
| |
| UL Listed;Type 3R |
| UL Listed; Type 3R 300 Volts Alternating Current |
| |
| 300 Volts Alternating Current |
| 300 Volts Alternating Current 200 Continuous Ampere |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase 60 Hertz |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase 60 Hertz 5.125L x 34.5W x 14H |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase 60 Hertz 5.125L x 34.5W x 14H 0 |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase 60 Hertz 5.125L x 34.5W x 14H 0 No Main Breaker Overhead or Underground |
| 300 Volts Alternating Current 200 Continuous Ampere 1 Phase 60 Hertz 5.125L x 34.5W x 14H 0 No Main Breaker Overhead or Underground with Center Wireway |
| |

| Enclosure | G90 Galvanized Steel with Powder Coat Finish |
|---------------------------|---|
| Jaw Quantity | 4 Terminal |
| Bypass Type | No Bypass |
| Number of Meter Positions | 3 Positions |
| Equipment Ground | Ground Lug |
| Hub Opening | Large Closing Plate |
| Line Side Wire Range | 4 AWG - 600 kcmil or Two 1/0 AWG - 250 kcmil |
| Load Side Wire Range | 6 AWG - 350 kcmil |
| Number Of Receptacles | 0 |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.