



MILBANK
ENERGY AT WORK

UC4964-O-WC-21-NST



Catalog Number	UC4964-O-WC-21-NST	Enclosure	G90 Galvanized Steel with Powder Coat Finish
Marketing Product Description	6 Terminal Ringless Plain Top Test Switch Prewired Nstar Massachusetts	Jaw Quantity	6 Terminal
UPC	784572269798	Bypass Type	No Bypass
Length (IN)	5.125	Number of Meter Positions	1 Position
Width (IN)	12	Equipment Ground	Ground Lug
Height (IN)	20	Hub Opening	Plain Top
Brand Name	Milbank	Line Side Wire Range	12 - 10 AWG
Type	Ringless Meter Socket	Load Side Wire Range	12 - 10 AWG
Special Features	Nstar Massachusetts	Number Of Receptacles	0
Application	Meter Socket		
Standard	UL Listed;Type 3R		
Voltage Rating	600 Volts Alternating Current		
Amperage Rating	20 Continuous Ampere		
Phase	1 Phase		
Frequency Rating	60 Hertz		
Size	5.125L x 12W x 20H		
Number Of Cutouts	0		
Cutout Size	No Main Breaker		
Cable Entry	Underground		
Terminal	Single Mechanical		
Insulation	Glass Polyester		
Mounting	Surface Mount		

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.