




MILBANK[®]
ENERGY AT WORK

TS07-0018



| | |
|-------------------------------|---|
| Catalog Number | TS07-0018 |
| Marketing Product Description | 7 Pole Test Switch Configuration 0018 |
| UPC | 784572132047 |
| Length (IN) | 2.906 |
| Width (IN) | 9.5 |
| Height (IN) | 3.5 |
| Weight (LB) | 3 |
| Brand Name | Milbank |
| Type | Instrument Rated Metering Test Switch |
| Application | Metering Accessory |
| Standard | UL Listed |
| Voltage Rating | 600 Volts Alternating Current |
| Amperage Rating | 20 Ampere |
| Number Of Poles | 7 |
| Frequency Rating | 60 Hertz |
| Connection | Stud |
| Material | Bronze Alloy |
| Enclosure | No Enclosure |
| Insulation | Non Metallic |
| Handle Color Arrangement | Red; Red; Red; Black; Black; Black; Black |

| | |
|------------------|---|
| Pole Arrangement | Barrier; Potential; Barrier; Barrier; Potential; Barrier; Barrier; Potential; Barrier; Current; Current Return; Current; Current Return |
|------------------|---|

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.