



**MILBANK**<sup>®</sup>  
ENERGY AT WORK

## U9800-RRL-QG-BL-NE



|                               |  |                           |  |
|-------------------------------|--|---------------------------|--|
| Catalog Number                | U9800-RRL-QG-BL-NE   | Mounting                  | Surface Mount  |
| Marketing Product Description | 4 Terminal Ringless Large Hub Open Adapt To Small Hub Open Lever Bypass 9-16 In Barrel Lock With Bracket Provision New England | Enclosure                 | G90 Galvanized Steel with Powder Coat Finish                   |
| UPC                           | 784572311923   | Jaw Quantity              | 4 Terminal   |
| Length (IN)                   | 4.844  | Bypass Type               | Lever Bypass   |
| Width (IN)                    | 10   | Number of Meter Positions | 1 Position   |
| Height (IN)                   | 18.5   | Equipment Ground          | Quadplex Ground  |
| Brand Name                    | Milbank  | Hub Opening               | Large Hub Opening Adapted to Small Hub Opening                 |
| Type                          | Ringless Meter Socket  | Line Side Wire Range      | 6 AWG - 350 kcmil  |
| Application                   | Meter Socket   | Load Side Wire Range      | 6 AWG - 350 kcmil  |
| Standard                      | UL Listed;Type 3R  | Barrel Lock Provision     | 9/16 Inch Knockout and Angle Bracket for Barrel Lock Provision |
| Voltage Rating                | 600 Volts Alternating Current  | Number Of Receptacles     | 0  |
| Amperage Rating               | 200 Continuous Ampere  |                           |  |
| Phase                         | 1 Phase  |                           |  |
| Frequency Rating              | 60 Hertz   |                           |  |
| Size                          | 4.844L x 10W x 18.5H   |                           |  |
| Number Of Cutouts             | 0  |                           |  |
| Cutout Size                   | No Main Breaker  |                           |  |
| Cable Entry                   | Overhead   |                           |  |
| Terminal                      | Lay in   |                           |  |
| Insulation                    | Glass Polyester  |                           |  |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.