MILBANK ENERGYAT WORK

U5101-XL-75



One Single Pole 20 Ampere Breaker and One Single Pole

ł				
	Catalog Number	U5101-XL-75	Cutout Size	
	Marketing Product Description	4 Terminal Ringless Small Closing Plate TT30 1450 520GR Surface Mount		
	UPC	784572324473	Cable Entry	
	Length (IN)	5.188	Terminal	
	Width (IN)	8.875	Insulation	
	Height (IN)	25	Mounting	
	Brand Name	Milbank	Enclosure	
	Туре	Ringless Meter Socket		
	Special Features	Single Pole 20 Ampere Breaker and Single Pole 30 Ampere Breaker and Double	Jaw Quantity	
			Bypass Type	
		Pole 50 Ampere Breaker	Number of M	
	Application	RV Power	Equipment C	
	Standard	UL Listed;Type 3R	Hub Opening	
	Voltage Rating	Up to 240 Volts Alternating	Line Side Wir	
		Current	Number Brar	
	Amperage Rating	125 Continuous Ampere	Number Of F	
	Phase	1 Phase	Receptacle C	
	Frequency Rating	60 Hertz		
	Size	5.188L x 8.875W x 25H		
	Number Of Cutouts	3		

	30 Ampere Breaker and One Double Pole 50 Ampere Breaker
Cable Entry	Overhead or Underground
Terminal	Lay in
Insulation	Glass Polyester
Mounting	Surface Mount
Enclosure	G90 Galvanized Steel with Powder Coat Finish
Jaw Quantity	4 Terminal
Bypass Type	No Bypass
Number of Meter Positions	Single Power Head
Equipment Ground	Ground Bar
Hub Opening	Small Closing Plate
Line Side Wire Range	6 AWG - 350 kcmil
Number Branch Circuits	2
Number Of Receptacles	3
Receptacle Configuration	One NEMA 14-50 and One NEMA TT30 and One NEMA 5-20 Ground Fault

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.