MILBANK ENERGYAT WORK

U5320-O-75GB



Two Single Pole 20 Ampere Breakers and Two Single Pole

| Catalog Number | U5320-O-75GB |
|-------------------------------|--|
| Marketing Product Description | 4 Terminal Ring Type Plain Top 1450 TT30 520GB Double Pedestal Direct Bury |
| UPC | 784572368767 |
| Length (IN) | 11.188 |
| Width (IN) | 8.884 |
| Height (IN) | 70.25 |
| Brand Name | Milbank |
| Туре | Ring Type Meter Socket |
| Special Features | Single Pole 20 Ampere Breaker and Single Pole 30 Ampere Breaker and Double Pole 50 Ampere Ground Fault Breaker |
| Application | RV Power |
| Standard | UL Listed;Type 3R |
| Voltage Rating | Up to 240 Volts Alternating Current |
| Amperage Rating | 125 Continuous Ampere |
| Phase | 1 Phase |
| Frequency Rating | 60 Hertz |
| Size | 11.188L x 8.884W x 70.25H |
| Number Of Cutouts | 6 |

| | 30 Ampere Breakers and Two Double Pole 50 Ampere Ground Fault Breakers |
|---------------------------|--|
| Cable Entry | Underground |
| Terminal | Double Mechanical |
| Insulation | Glass Polyester |
| Mounting | Pedestal |
| Enclosure | G90 Galvanized Steel with Powder Coat Finish |
| Jaw Quantity | 4 Terminal |
| Bypass Type | No Bypass |
| Number of Meter Positions | Double Power Head |
| Equipment Ground | 2 Barrel Ground Lug and Ground Bar |
| Hub Opening | Plain Top |
| Line Side Wire Range | 6 AWG - 350 kcmil |
| Number Branch Circuits | 4 |
| Number Of Receptacles | 6 |
| Receptacle Configuration | Two NEMA 14-50 and Two NEMA TT30 and Two NEMA 5-20 Ground Fault |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.

Cutout Size