



MILBANK
ENERGY AT WORK

U5784-O-200-CB



| | | | |
|-------------------------------|---|---------------------------|--|
| Catalog Number | U5784-O-200-CB | Mounting | Surface Mount |
| Marketing Product Description | 4 Terminal Ringless Plain Top Lever Bypass 1-200 Ampere Main Breaker 480 Volt Cold Sequence | Enclosure | G90 Galvanized Steel with Powder Coat Finish |
| UPC | 784572478879 | Jaw Quantity | 5 Terminal |
| Length (IN) | 4.844 | Bypass Type | Lever Bypass |
| Width (IN) | 26 | Number of Meter Positions | 1 Position |
| Height (IN) | 28 | Equipment Ground | Grounding Stud |
| Brand Name | Milbank | Hub Opening | Plain Top |
| Type | Ringless Meter Socket | Line Side Wire Range | 1/0 AWG - 350kcmil |
| Application | Meter Socket With Main | Load Side Wire Range | 6 AWG - 350 kcmil |
| Standard | UL Listed;Type 3R | Number Of Receptacles | 0 |
| Voltage Rating | Up to 240 Volts Alternating Current | | |
| Amperage Rating | 200 Continuous Ampere | | |
| Phase | 1 Phase | | |
| Frequency Rating | 60 Hertz | | |
| Size | 4.844L x 26W x 28H | | |
| Number Of Cutouts | 1 | | |
| Cutout Size | One 200 Ampere Main Breaker | | |
| Cable Entry | Underground | | |
| Terminal | Single Mechanical | | |
| Insulation | Glass Polyester | | |

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.