




MILBANK
ENERGY AT WORK

U7487-YL-KK-CPSB



Catalog Number	U7487-YL-KK-CPSB
Marketing Product Description	4 Terminal Ringless 1.25 In Hub Horn Bypass City Public Service Board Of San Antonio
UPC	784572483200
Length (IN)	3.313
Width (IN)	8
Height (IN)	11.5
Brand Name	Milbank
Type	Ringless Meter Socket
Application	Meter Socket
Standard	UL Listed;Type 3R
Voltage Rating	600 Volts Alternating Current
Amperage Rating	125 Continuous Ampere
Phase	1 Phase
Frequency Rating	60 Hertz
Size	3.313L x 8W x 11.5H
Number Of Cutouts	0
Cutout Size	No Main Breaker
Cable Entry	Overhead or Underground
Terminal	Lay in
Insulation	Glass Polyester
Mounting	Surface Mount

Enclosure G90 Galvanized Steel with Powder Coat Finish

Jaw Quantity 4 Terminal

Bypass Type Horn Bypass

Number of Meter Positions 1 Position

Equipment Ground Bonded Neutral

Hub Opening 1 1/4 Inch Hub

Line Side Wire Range 6 - 2/0 AWG

Load Side Wire Range 6 - 2/0 AWG

Number Of Receptacles 0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.