

U2855-X-KK-PED-CECHA



Catalog Number	U2855-X-KK-PED-CECHA
Marketing Product Description	4 Terminal Ringless Large Closing Plate Horn Bypass 5 Position 5-125 Ampere Main Breaker Provision Pedestal Mount Provision Vertical Commonwealth Edison Chicago Housing Authority
UPC	784572726789
Length (IN)	4.84
Width (IN)	31
Height (IN)	37
Brand Name	Milbank
Туре	Ringless Meter Socket
Application	Meter Socket With Main
	motor occitor man man
Standard	UL Listed;Type 3R
Standard	UL Listed;Type 3R Up to 240 Volts Alternating
Standard Voltage Rating	UL Listed;Type 3R Up to 240 Volts Alternating Current
Standard Voltage Rating Amperage Rating	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere
Standard Voltage Rating Amperage Rating Phase	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere 1 Phase
Standard Voltage Rating Amperage Rating Phase Frequency Rating	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere 1 Phase 60 Hertz
Standard Voltage Rating Amperage Rating Phase Frequency Rating Size	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere 1 Phase 60 Hertz 4.84L x 31W x 37H
Standard Voltage Rating Amperage Rating Phase Frequency Rating Size Number Of Cutouts	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere 1 Phase 60 Hertz 4.84L x 31W x 37H 6
Standard Voltage Rating Amperage Rating Phase Frequency Rating Size Number Of Cutouts Cutout Size	UL Listed; Type 3R Up to 240 Volts Alternating Current 125 Continuous Ampere 1 Phase 60 Hertz 4.84L x 31W x 37H 6 Breaker Provision

Insulation	Glass Polyester
Mounting	Surface Mount
Enclosure	G90 Galvanized Steel with Powder Coat Finish
Jaw Quantity	4 Terminal
Bypass Type	Horn Bypass
Number of Meter Positions	5 Positions
Equipment Ground	Ground Lug
Hub Opening	Large Closing Plate
Number Of Receptacles	0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.